

Fire Protection and Prevention

- * Daily housekeeping.
- * Properly dispose of combustible and flammable materials.
 - * Metal containers required for accumulations.
- * Properly store combustible and flammable materials.
 - * Approved containers and tanks for storage and handling flammable and combustible liquids. (one (1) gallon or more)
 - * Containers and tanks legibly marked to indicate contents.
 - * No more than twenty-five (25) gallons of flammable or combustible liquid stored in a room, unless they are stored in an approved storage cabinet(s).
 - * Outside storage of flammable or combustible liquid shall not exceed 1,100 gallons in any one pile or area.
- * All fires and open flames must be attended.
- * Adequate fire suppression equipment.
 - * Properly maintained.
 - * Conspicuously marked.
 - * Periodically inspected.
 - * Fire suppression equipment must be available within 100 feet travel distance; 50 feet in areas where flammable or combustible liquid is stored.
 - * Fire extinguisher available for each 3,000 feet of building area.

Fire Protection and Prevention

- * Temporary heating devices operated and maintained according to the manufacturer's specifications and instructions.
 - * Proper clearance from combustible materials.
 - * Adequate ventilation.
 - * Proper fuel.
 - * Safety switch(s).
 - * Follow ignition instructions.
- * Establish "No Smoking" and "No Open Flame" areas.
- * Establish "Smoking Permitted" areas.
- * Electrical wiring and equipment maintained in safe condition.
- * Engine exhaust routed away from combustibles.
- * Sufficient fire lanes established to allow rapid access for fire control apparatus into the storage or work areas.